

Job Name/Location:

Tag #:

Date:

For:	File	Resubmit
	Approval	Other _____

PO No.:

Architect:

GC:

Engr:

Mech:

Rep:
(Company)

(Project Manager)



PQSH1201

Outdoor Unit Drain Pan Heater



Electrical:

Power Requirements	Wiring Harness Plugs into Outdoor Unit Control Board Terminal
Control Requirements	Wiring Harness Plugs into Outdoor Unit Control Board Terminal
Capacity (W)	120W

Compatibility:

Single-Zone Art Cool™ Mirror Outdoor Units: LSU180HSV5, LAU240HSV3; Single-Zone High Efficiency Outdoor Units: LSU180HSV5; Single-Zone Extending Piping Outdoor Units: LSU303HLV, LSU363HLV.

Notes:

1. Follow all installation instructions in the Base Pan Heater Installation manual.
2. Ensure that there is at least 1-3/16" clearance from the outdoor unit fan.
3. As a safety precaution, the heater will not energize if the outdoor temperature is higher than 32°F.
4. Appearances may vary depending on model.
5. To determine the date of the outdoor unit manufacture, refer to the first three digits of the serial number. First digit represents the year; second and third digits represent the month. For example, SN 503XXXXXX indicates date of manufacture of March 2015.

